



**Before Coating-GI Sheet**



**After Cooling Treatment-  
GI Sheet**



**Cooling Treatment with  
Transparent coat- GI  
Sheet**

March, 2012

<b>Time</b>	<b>Before coating (In Degg. C)</b>	<b>After coating (In Degg. C)</b>	<b>Temp. Diff. (In Degg. C)</b>
<b>12 PM</b>	52	47	5
<b>1 PM</b>	54	46	8
<b>2 PM</b>	57	48	9
<b>3 PM</b>	58	46	12

## References:-

1) Alstom Hydro Pvt. Ltd

**Place:-Maneja, Vadodara**

Contact Person:- Mr. Prashant setty

Contact Number:-0265 6613555.